



**ENGINEERING SERVICES DEPARTMENT**  
**2220 MAGNOLIA STREET**  
**CERES, CA 95307**  
**(209) 538-5792**  
**FAX (209) 538-5759**

**CITY COUNCIL**  
**CHRIS VIERRA, MAYOR**  
**KEN LANE, BRETT DUROSSETTE**  
**LINDA RYNO, MIKE KLINE**

**ADDENDUM NUMBER 1**

Date: October 6, 2016

**PROJECT: SERVICE ROAD SEWER EXTENSION  
CROWS LANDING ROAD TO WWTP**

Addendum Number 1 is being issued to the Notice to Bidders, Specifications and Plans, for the Service Road Sewer Extension Crows Landing Road to WWTP. Bids for this proposal are to be opened on Wednesday, October 12, 2016 at 2:00 p.m.

The following is to be changed:

1. Bid Item # 31 - Regarding by-pass pumping, average inflow into the WWTP Headworks will vary between 2.3 and 3.0 MGD depending on weather conditions. Low flow periods are between 10:00 p.m. and 6:00 a.m. Contractor is to anticipate the amount of time it takes to complete the tie in and to allow for concrete curing time. During this time the contractor will be required to handle the inflows to the WWTP and to provide redundancy for any pumps being used.

**IF YOU SUBMIT A BID, A SIGNED COPY OF THIS ADDENDUM MUST BE ATTACHED HERETO.**

Sincerely,

Leonard P. Guillette  
Engineering Project Manager  
Engineering Services Department

Contractor \_\_\_\_\_

Signature \_\_\_\_\_

Date \_\_\_\_\_